



**Assistant Engineer (Elect.)**  
**CIVIL CONSTRUCTION WING**

**By Hand**  
**PRASAR BHARAT**  
(BROADCASTING CORPORATION OF INDIA)

Telefax: 2493 6094  
Telephone: 2491 1501  
Email: ccwelect@rediffmail.com

# All India Radio & Doordarshan, First floor, Old Bldg, TV Centre, Worli, Mumbai #  
No: - AE (E)/MUM/2010-11/10-NIQ / NIT Dated :

**SHORT NOTICE INVITING QUOTATION**

Item rate sealed quotations are hereby invited on behalf of the President of India by the undersigned, from the agencies for the following work on 10.08.2010 and will be opened on same day at 3.30 P.M in the office of the Assistant Engineer (Elect), CCW, AIR, Mumbai.

**Name of work:- I E I i/c fans & fittings on 3rd floor CBS Rooms at AIR, NBH, Mumbai.**  
**(SH:- Rewiring of IEI and Replacement of fittings and other allied works)**

<u>Sr. No.</u>	<u>Description Of Item</u>	<u>Qty</u>	<u>Rate</u>	<u>Unit</u>	<u>Amount</u>
	As per attached schedule	1 (One)			
	<b>Total</b>				

Rupees Conditions:

1. No advance payment will be made.
2. The time limit for the work is 10 (ten)days.
3. Rates should be inclusive of all nothing extra shall be paid on any account.
4. This office reserves right to cancel & reject the quotation order with out assigning any reason.

To,

Assistant Engineer (Elect)  
CCW: AIR: MUMBAI

M/s

Copy to for information to:-

1. The Executive Engineer (Elect.), CCW, AIR, Mumbai.
2. Notice Board.
3. Spare copies.

Assistant Engineer (Elect)

**Schedule of Work**  
**Name of work:- I E I i/c fans & fittings on 3rd floor CBS Rooms at AIR, NBH, Mumbai.**  
**(SH:- Rewiring of IEI and Replacement of fittings and other allied works)**

S.N	Description	Qty	Unit	Rate	Amount
1	Wiring for light point/ fan point/ exhaust fan point/callbell point with 1.5 sq.mm FR PVC insulated copper conductor single core cable in surface/recessed PVC conduit, with modular type switch, modular plate suitable GI box and earthing the point with 1.5 sq.mm FR PVC insulated copper conductor single core cable etc as required - Group 'C'	5.00	points		
2	Wiring for circuit/submain wiring alongwith earth wire with the following sizes of PVC insulated copper conductor, single core cable in surface /recessed conduit as required				
	a) 2 X 2.5 sq.mm + 1 X 2.5 sq.mm earth wire	25.00	mtr		
	b) 2 X 1.5 sq.mm + 1 X 1.5 sq.mm earth wire	10.00	mtr		
3	Wiring for light/ power plug with 2 X 4 sq.mm FR PVC insulated copper conductor single core cable in surface/recessed PVC conduit alongwith 1 No 4 sq mm FR PVC insulated copper conductor single core cable for loop earthing as required.	25.00	mtr		
4	Wiring for light/ power plug with 4 X 4 sq.mm FR PVC insulated copper conductor single core cable in surface/recessed PVC conduit alongwith 2 Nos 4 sq mm FR PVC insulated copper conductor single core cable for loop earthing as required	21.00	mtr		
5	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 3 pin 5/6 amps modular socket outlet and 5/6 amps modular switch, connection, painting etc. as required. ( For light plus to be used non residential building)	4.00	mtr		
6	Supplying and fixing suitable size GI box with modular plate and cover in front on surface or in recess, including providing and fixing 6 pin 15/16 and 5/6 amps modular socket outlet and 15/16 amps modular socket outlet and 15/16 amps modular switch, connection, painting etc. as required.	3.00	mtr		
7	S/I/T/Commissioning of 1 x 28 watt T5 fluorescent lamp mirror optic fitting with 28 watt T5 tube duly wired with electronic choke tube holder directly on ceiling/wall complete etc as reqd ( EYE LIGHT MAKE .	5.00	Job		
8	S/I/T/Commissioning of Wall mounting fan of 400 mm sweep in size with built in regulator complete etc as reqd.(Crompton make)	1.00	Job		
9	S/I/T/Commissioning of 12 way SP& N double door M C B DB with busbar, dinbar, earthing stud with 40 Amp SP&N incomer - 1no, 10 amp MCB-6no & 16 amp-4no complete etc as reqd.	1.00	job		
10	Supplying and fixing following way, single pole and neutral, sheet steel, MCB distribution board, 240 volts, on surface/recess, complete with tinned copper busbar, neutral busbar, earth bar, din bar, detachable gland plate, interconnections, phosphatized and powder painted including earthing etc. as required (But without MCB/RCCB/Isolator)				
	12 way, Double door	1.00	Each		
11	Supplying and fixing 5 amps to 32 amps rating, 240 volts, 'B' series, miniature circuit breaker suitable for lighting and other loads of following poles in the existing MCB DB complete with connections, testing and commissioning etc. as required.				
	a) Single pole	10.00	Each		
	Supplying and fixing following rating, double pole 240 volts, isolator in the existing MCB DB complete with connections, testing and commissioning etc. as required				
	a) 63 amp	1.00	Each		

Junior Engineer (Elect)  
CCW, AIR, Mumbai

Assistant Engineer (Elect)  
CCW, AIR, Mumbai.

Vertical line on the left side of the page.