

PRASAR BHARATI
(BROADCASTING CORPORATION OF INDIA)
OFFICE OF THE CHIEF ENGINEER (SOUTH ZONE)
ALL INDIA RADIO & DOORDARSHAN
SWAMY SIVANANDA SALAI, CHENNAI - 600 005

No. CESZ/PUR-II/PSEA/NIT-01/2011-12/

Date: 15-07-2011

CORRIGENDUM

SUB.: ENQUIRY FOR THE NOTICE INVITING TENDER FOR THE SITC OF 11 KV, 3 PHASE, 250 MVA, 400 A, 50 HZ, **6 PANEL, HT SWITCHGEAR** FOR HIGH POWER TRANSMITTER AT ALL INDIA RADIO, VIJAYAWADA, TIRUCHIRAPALLI, AVADI & BANGALORE AND **4 PANEL HT SWITCHGEAR** FOR HIGH POWER TRANSMITTER AT ALL INDIA RADIO, DHARWAD.

Ref.: This office NIT Enquiry of even No. dated 13.07.2011.

Sir,


With reference to the subject cited above, this is to inform that, a **Pre-bid Meeting will be held on 27.07.2011 at 3.00 P.M. in the Conference Hall of this office.**

Attending pre bid meeting is mandatory for participation in the Technical Bid / Commercial Bid as this work involves SITC of HT switchgear system in the Transmitter Building without causing any service breakdown. Also it is felt essential that the bidder should know the site conditions before offering the Tender. They may contact the DDE (Engg.)(Purchase), AIR & DD, Chennai - 600 005, for further details regarding Pre-Bid meeting.

The following Corrections in the Tender Document may be noted.

Sl. No	Description as mentioned in the Tender Document	Correction
1	Section - IV, Schedule of Requirements (Price Bid), Sl.No.1 Supply of 11 KV, 400A, 250 KVA , 3 phase, 50Hz, 6 Panel HT Switch Gear for AIR, Vijayawada, Tiruchirapalli, Avadi & Bangalore And Supply of 11 KV, 400A, 250 KVA , 3 phase, 50Hz, 4 Panel HT Switch Gear for AIR, Dharwad.	May be read as: Section - IV, Schedule of Requirements (Price Bid), Sl.No.1 Supply of 11 KV, 400A, 250 MVA , 3 phase, 50Hz, 6 Panel HT Switch Gear for AIR, Vijayawada, Tiruchirapalli, Avadi & Bangalore And Supply of 11 KV, 400A, 250 MVA , 3 phase, 50Hz, 4 Panel HT Switch Gear for AIR, Dharwad.
2	Section-III, Technical Specifications, 6 Panel/4 Panel; Technical Parameters, Sl.No3.2.1(f) HT Switch Gear:	The dimensions of the panel indicated in the tender document are only approximate. Tenderers are required to submit their Panel dimensions.

Yours faithfully,


(T.SHANMUGARAJU)
DY. DIRECTOR (ENGG) (PURCHASE)
for Chief Engineer (SZ)
Ph.No.: 044 - 25382853