

**PRASAR BHARATI  
(BROADCASTING CORPORATION OF INDIA)  
OFFICE OF THE ADDITIONAL DIRECTOR GENERAL(E)(SOUTH ZONE)  
ALL INDIA RADIO & DOORDARSHAN  
SWAMY SIVANANDA SALAI, CHENNAI - 600 005**

**No. ADG(E)(SZ)/PUR/ 74/PSEA/2011-12/**

**Date: 18-01-2012**

**CORRIGENDUM**

**SUB.:** CORRIGENDUM ON the Enquiry for the SITC of LT Panel for Doordarshan, HPT  
Visakhapatnam – Reg.

**Ref.:** This office Enquiry of even No. dated 05.01.2012.

Sir,

With reference to the subject cited above, the following corrections has been made, may please be noted.

Page No	Existing	To be read as
13	The size of the panels mentioned below the GA drawing given in feet.	<b>The size of the panels mentioned below the GA drawing may please be read as inches.</b>
14,15	In single line diagram it shows Voltmeter and Ampere meter	<b>Multi function meter is required</b>

Yours faithfully,

**( JOTHI VIJAYAKUMAR )  
Assistant Engineer(PUR)  
for ADG(E) (SZ)**